

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

**1319536 Ontario Limited**

6378 Trafalgar Rd Hornby  
Milton

**Sector:** Miscellaneous Communal  
**Ministry Office:** Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### PHOSPHORUS

#### CofA/Permit Non-Compliance

October 1, 2010 - October 31, 2010	10	mg/L	mon avg	1 exceedance	11.4	11.4	Other	Voluntary Abatement Program Underway
---------------------------------------	----	------	---------	--------------	------	------	-------	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### 876705 Ontario Limited - Grog's Pub & Grill

8604 Lakeshore Rd P.O. Boc 79  
Lambton Shores

**Sector:** Miscellaneous Communal  
**Ministry Office:** Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>BIOCHEMICAL OXYGEN DEMAND</b>								
<b>CofA/Permit Non-Compliance</b>								
February 1, 2010 - February 28, 2010	10	mg/L	mon avg	1 exceedance	13	13	Operational Process Modification	Assessment Underway

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Belmac Estate Properties Inc. - Beverly Hills Estates

1284 8th Concession Rd W  
Hamilton

**Sector:** Miscellaneous Communal  
**Ministry Office:** Hamilton

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### SUSPENDED SOLIDS

#### CofA/Permit Non-Compliance

November 17, 2010	12	mg/L	/d	1 exceedance	33	33	Operational Process Modification	Assessment Complete - No Action Required
-------------------	----	------	----	--------------	----	----	----------------------------------	--

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Bigwin Island Golf Club

Lot 7 Plan 35M-698  
Lake of Bays

**Sector:** Miscellaneous Communal  
**Ministry Office:** Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>SUSPENDED SOLIDS</b>								
<b>CofA/Permit Non-Compliance</b>								
September 01, 2010	10	mg/L	mon avg	1 exceedance	13.5	13.5	Action Plan Submitted - Implementing Improvements	Assessment Complete - No Action Required

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### City of Greater Sudbury - Chelmsford Sewage Treatment Plant

300 Laurette St Lot 3, Concession 2  
Greater Sudbury

**Sector:** Municipal Sewage  
**Ministry Office:** Sudbury

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### ESCHERICHIA COLI

#### CofA/Permit Non-Compliance

September 29, 2010	200	CT/100 mL	mon avg	1 exceedance	100000	100000	Training/Procedure Change	Assessment Complete - No Action Required
--------------------	-----	--------------	---------	--------------	--------	--------	---------------------------	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

### TOTAL AMMONIA NITROGEN

#### CofA/Permit Non-Compliance

May 1, 2010 - October 31, 2010	2	mg/L	seasonal avg	1 exceedance	2.2	2.2	Action Plan Submitted - Implementing Improvements, Equipment Modified - Repaired - Replaced or Re- calibrated, Operational Process Modification	Assessment Complete - No Action Required
-----------------------------------	---	------	-----------------	--------------	-----	-----	--	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### City of Greater Sudbury - Lively Sewage Treatment Plant

Waters Township  
Greater Sudbury

**Sector:** Municipal Sewage  
**Ministry Office:** Sudbury

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>ESCHERICHIA COLI</b>								
<b>CofA/Permit Non-Compliance</b>								
June 25, 2010	200	CT/100 mL	mon avg	1 exceedance	100000	100000	Other, Training/Procedure Change	Assessment Complete - No Action Required

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### City of Greater Sudbury - Sudbury Wastewater Treatment Plant

1271 Kelly Lake Road  
Greater Sudbury

**Sector:** Municipal Sewage  
**Ministry Office:** Sudbury

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>ESCHERICHIA COLI</b>								
<b>CofA/Permit Non-Compliance</b>								
December 01, 2010	200	cfu/100 ml	mon avg. on a geo. mean density	1 exceedance	100000	100000	Other	Voluntary Abatement Program Underway

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### City of Greater Sudbury - Wahnapitae Sewage Treatment Lagoon

Geographic Township of Dryden  
Greater Sudbury

**Sector:** Municipal Sewage  
**Ministry Office:** Sudbury

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### SUSPENDED SOLIDS

##### CofA/Permit Non-Compliance

November 1, 2010 - November 30, 2010	40	mg/L	/mon	1 exceedance	45	45	Other	Assessment Complete - Incident Resolved
---	----	------	------	--------------	----	----	-------	--

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### City of Greater Sudbury - Walden Sewage Treatment Plant

Waters Township  
Greater Sudbury

**Sector:** Municipal Sewage  
**Ministry Office:** Sudbury

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>ESCHERICHIA COLI</b>								
<b>CofA/Permit Non-Compliance</b>								
March 18, 2010	200	CT/100 mL	mon avg	1 exceedance	100000	100000	Training/Procedure Change	Assessment Complete - No Action Required
April 14, 2010	200	CT/100 mL	mon avg	1 exceedance	100000	100000	Training/Procedure Change	Assessment Complete - No Action Required

**Total CofA/Permit Non-Compliance = 2 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### City of Hamilton - Dundas WWTP

135 King St E Dundas  
Hamilton

**Sector:** Municipal Sewage  
**Ministry Office:** Hamilton

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### BIOCHEMICAL OXYGEN DEMAND

#### CofA/Permit Non-Compliance

July 06, 2010	91	kg/d	/d	1 exceedance	114.06	114.06	Other	Assessment Complete - Incident Resolved
---------------	----	------	----	--------------	--------	--------	-------	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

### TOTAL KJELDAHL NITROGEN

#### CofA/Permit Non-Compliance

September 30, 2010	36.4	kg/d	/d	1 exceedance	77.12	77.12	Equipment Modified - Repaired - Replaced or Re-calibrated	Assessment Complete - Incident Resolved
--------------------	------	------	----	--------------	-------	-------	---	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### City of Hamilton - Waterdown WWTP

250 Main St S Waterdown  
Hamilton

**Sector:** Municipal Sewage  
**Ministry Office:** Hamilton

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### BIOCHEMICAL OXYGEN DEMAND

#### CofA/Permit Non-Compliance

February 16, 2010	20.45	kg/d	/d	1 exceedance	55.52	55.52	Additional Monitoring Underway	Assessment Complete - No Action Required
-------------------	-------	------	----	--------------	-------	-------	--------------------------------	--

**Total CofA/Permit Non-Compliance = 1 exceedance**

### PHOSPHORUS

#### Policy/Guideline Non-Conformance

January 31, 2010 - February 28, 2010	0.3	mg/l	mon avg	2 exceedances	0.35	0.35	None Required	Assessment Complete - No Action Required
---	-----	------	---------	---------------	------	------	---------------	--

**Total Policy/Guideline Non-Conformance = 2 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### ClubLink Corporation - Emerald Hills Golf Club

14001 Warden Ave Stouffville  
Whitchurch-Stouffville

**Sector:** Miscellaneous Communal  
**Ministry Office:** York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### NITROGEN

#### CofA/Permit Non-Compliance

January 1, 2010 - December 31, 2010	22	ppm	mon avg	5 exceedances	23	24	Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway
--	----	-----	---------	---------------	----	----	--	---

**Total CofA/Permit Non-Compliance = 5 exceedances**

### TOTAL AMMONIA NITROGEN

#### CofA/Permit Non-Compliance

January 1, 2010 - December 31, 2010	2.5	ppm	mon avg	8 exceedances	2.6	5.5	Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway
--	-----	-----	---------	---------------	-----	-----	--	---

**Total CofA/Permit Non-Compliance = 8 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### ClubLink Corporation - King Valley Golf Club

15675 Dufferin Street, King City  
King

**Sector:** Miscellaneous Communal  
**Ministry Office:** York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>CARBONACEOUS BIOCHEMICAL OXYGEN DEMAND</b>								
<b>CofA/Permit Non-Compliance</b>								
January 1, 2010 - December 31, 2010	30	ppm	mon avg	2 exceedances	31	33	Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway
<b>Total CofA/Permit Non-Compliance = 2 exceedances</b>								
<b>ESCHERICHIA COLI</b>								
<b>CofA/Permit Non-Compliance</b>								
January 1, 2010 - December 31, 2010	100	CT/100 mL	mon avg	1 exceedance	106	106	Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway
<b>Total CofA/Permit Non-Compliance = 1 exceedance</b>								
<b>NITROGEN</b>								
<b>CofA/Permit Non-Compliance</b>								
January 1, 2010 - December 31, 2010	22	ppm	mon avg	7 exceedances	23	27	Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway
<b>Total CofA/Permit Non-Compliance = 7 exceedances</b>								
<b>SUSPENDED SOLIDS</b>								
<b>CofA/Permit Non-Compliance</b>								
January 1, 2010 - December 31, 2010	30	ppm	mon avg	1 exceedance	35	35	Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### ClubLink Corporation - King Valley Golf Club

15675 Dufferin Street, King City  
King

**Sector:** Miscellaneous Communal  
**Ministry Office:** York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

### TOTAL AMMONIA NITROGEN

#### CofA/Permit Non-Compliance

January 1, 2010 - December 31, 2010	2.5	ppm	mon avg	12 exceedances	3.9	15	Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway
--	-----	-----	---------	----------------	-----	----	--	---

**Total CofA/Permit Non-Compliance = 12 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### ClubLink Corporation - Wyndance Golf Club

15675 Dufferin Street, King City  
Uxbridge

**Sector:** Miscellaneous Communal  
**Ministry Office:** York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### PHOSPHORUS

#### CofA/Permit Non-Compliance

May 1, 2010 - May 31, 2010	1	mg/L	mon avg	2 exceedances	1.1	1.3	Other	Assessment Complete - Incident Resolved
-------------------------------	---	------	---------	---------------	-----	-----	-------	--

**Total CofA/Permit Non-Compliance = 2 exceedances**

### SUSPENDED SOLIDS

#### CofA/Permit Non-Compliance

April 1, 2010 - April 30, 2010	25	mg/L	mon avg	2 exceedances	29	33	Other	Assessment Complete - Incident Resolved
-----------------------------------	----	------	---------	---------------	----	----	-------	--

**Total CofA/Permit Non-Compliance = 2 exceedances**

### TOTAL AMMONIA NITROGEN

#### CofA/Permit Non-Compliance

March 1, 2010 - March 31, 2010	3	mg/L	mon avg	1 exceedance	5.6	5.6	Action Plan Submitted - Implementing Improvements, Operational Process Modification	Assessment Complete - Incident Resolved, Voluntary Abatement Program Underway
May 1, 2010 - May 31, 2010	3	mg/L	mon avg	1 exceedance	6	6	Other	Assessment Complete - Incident Resolved

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### ClubLink Corporation - Wyndance Golf Club

15675 Dufferin Street, King City  
Uxbridge

**Sector:** Miscellaneous Communal  
**Ministry Office:** York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
June 1, 2010 - June 30, 2010	3	mg/L	mon avg	1 exceedance	6.2	6.2	Other	Assessment Complete - Incident Resolved

**Total CofA/Permit Non-Compliance = 3 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Crest Support Services (Meadowcrest) Inc.

13570 Elginfield Rd  
Lucan Biddulph

**Sector:** Miscellaneous Communal  
**Ministry Office:** London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### ESCHERICHIA COLI

#### CofA/Permit Non-Compliance

October 1, 2010 - October 31, 2010	200	CT/100 mL	mon avg. on a geo. mean density	1 exceedance	946	946	Action Plan Submitted - Implementing Improvements, Additional Monitoring Underway, Conducting Study, Equipment Modified - Repaired - Replaced or Re- calibrated	Assessment Underway, Voluntary Abatement Program Underway
---------------------------------------	-----	--------------	--	--------------	-----	-----	---	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

### PHOSPHORUS

#### CofA/Permit Non-Compliance

May 1, 2010 - November 30, 2010	0.5	mg/L	mon avg	5 exceedances	0.76	1.25	Action Plan Submitted - Implementing Improvements, Additional Monitoring Underway, Conducting Study, Equipment Modified - Repaired - Replaced or Re- calibrated	Assessment Underway, Voluntary Abatement Program Underway
------------------------------------	-----	------	---------	---------------	------	------	---	---

**Total CofA/Permit Non-Compliance = 5 exceedances**

### SUSPENDED SOLIDS

#### CofA/Permit Non-Compliance

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Crest Support Services (Meadowcrest) Inc.

13570 Elginfield Rd  
Lucan Biddulph

**Sector:** Miscellaneous Communal  
**Ministry Office:** London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
May 1, 2010 - November 30, 2010	10	mg/L	mon avg	5 exceedances	11.75	26.83	Action Plan Submitted - Implementing Improvements, Additional Monitoring Underway, Conducting Study, Equipment Modified - Repaired - Replaced or Re- calibrated	Assessment Underway, Voluntary Abatement Program Underway
January 1, 2010 - December 31, 2010	15	mg/L	mon avg	4 exceedances	175.75	20.6	Action Plan Submitted - Implementing Improvements, Additional Monitoring Underway, Conducting Study, Equipment Modified - Repaired - Replaced or Re- calibrated	Assessment Underway, Voluntary Abatement Program Underway

**Total CofA/Permit Non-Compliance = 9 exceedances**

### TOTAL AMMONIA NITROGEN

#### CofA/Permit Non-Compliance

April 1, 2010 - April 30, 2010	5	mg/L	mon avg	1 exceedance	8.2	8.2	Action Plan Submitted - Implementing Improvements, Additional Monitoring Underway, Conducting Study, Equipment Modified - Repaired - Replaced or Re- calibrated	Assessment Underway, Voluntary Abatement Program Underway
-----------------------------------	---	------	---------	--------------	-----	-----	---	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Eagle Landing Mobile Home Park

2233 Eagle St  
Fort Erie

**Sector:** Miscellaneous Communal  
**Ministry Office:** Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### BIOCHEMICAL OXYGEN DEMAND

#### CofA/Permit Non-Compliance

January 1, 2010 - December 31, 2010	0.26	kg/d	annual avg	1 exceedance	0.32	0.32	Training/Procedure Change	Other Abatement Action Taken
--	------	------	------------	--------------	------	------	---------------------------	------------------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

### SUSPENDED SOLIDS

#### CofA/Permit Non-Compliance

January 1, 2010 - December 31, 2010	0.34	kg/d	annual avg	1 exceedance	0.51	0.51	Training/Procedure Change	Other Abatement Action Taken
--	------	------	------------	--------------	------	------	---------------------------	------------------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Earth Rangers Foundation

9520 Pine Valley Dr Woodbridge  
Vaughan

**Sector:** Municipal Sewage  
**Ministry Office:** York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### BIOCHEMICAL OXYGEN DEMAND

#### CofA/Permit Non-Compliance

April 1, 2010 - April 30, 2010	10	mg/L	mon avg	1 exceedance	14	14	Other	Assessment Complete - No Action Required
-----------------------------------	----	------	---------	--------------	----	----	-------	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

### PHOSPHORUS

#### CofA/Permit Non-Compliance

July 1, 2010 - July 31, 2010	0.2	mg/L	mon avg	1 exceedance	0.352	0.352	Other	Assessment Complete - No Action Required
November 1, 2010 - November 30, 2010	0.2	mg/L	mon avg	1 exceedance	0.228	0.228	Conducting Study	Assessment Underway

**Total CofA/Permit Non-Compliance = 2 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Georgian Villas Inc. - The Corporation of the Township of Georgian Bluffs

Owen Sound Bay along Grey County Rd #1  
Georgian Bluffs

**Sector:** Municipal Sewage  
**Ministry Office:** Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### SUSPENDED SOLIDS

##### CofA/Permit Non-Compliance

May 1, 2010 - May 31, 2010	10	mg/L	mon avg	1 exceedance	13.75	13.75	Additional Monitoring Underway, Equipment Modified - Repaired - Replaced or Re-calibrated, New/Modified Sampling Program Underway	Assessment Complete - Incident Resolved
-------------------------------	----	------	---------	--------------	-------	-------	--	--

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Golf Leaseholds Limited

2694 Wilson Dr Minesing  
Springwater

**Sector:** Miscellaneous Communal  
**Ministry Office:** Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>PHOSPHORUS</b>								
<b>CofA/Permit Non-Compliance</b>								
July 1, 2010 - July 31, 2010	1	mg/L	mon avg	1 exceedance	5.22	5.22	New Equipment or Treatment Process Installed	Assessment Complete - No Action Required

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Granite Golf Inc.

30 - 2699 York Durham Rd  
Uxbridge

**Sector:** Municipal Sewage  
**Ministry Office:** York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### PHOSPHORUS

#### CofA/Permit Non-Compliance

May 1, 2010 - May 31, 2010	0.3	ppm	mon avg	1 exceedance	0.5	0.5	Equipment Modified - Repaired - Replaced or Re- calibrated	Assessment Complete - Incident Resolved
-------------------------------	-----	-----	---------	--------------	-----	-----	--	--

**Total CofA/Permit Non-Compliance = 1 exceedance**

### SUSPENDED SOLIDS

#### CofA/Permit Non-Compliance

June 1, 2010 - June 30, 2010	5	ppm	mon avg	1 exceedance	5.3	5.3	Equipment Modified - Repaired - Replaced or Re- calibrated	Assessment Complete - Incident Resolved
---------------------------------	---	-----	---------	--------------	-----	-----	--	--

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Greater Napanee Water Supply and Pollution Control Public Utilities Commission - Deseronto WPCP

322 Water St  
Deseronto

**Sector:** Municipal Sewage  
**Ministry Office:** Belleville

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### PHOSPHORUS

##### CofA/Permit Non-Compliance

June 1, 2010 - June 30, 2010	0.3	mg/L	/mon	1 exceedance	0.49	0.49	Other	Assessment Underway
---------------------------------	-----	------	------	--------------	------	------	-------	---------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

#### SUSPENDED SOLIDS

##### CofA/Permit Non-Compliance

June 1, 2010 - June 30, 2010	0.48	kg/d	/mon	1 exceedance	0.54	0.54	Other	Assessment Underway
---------------------------------	------	------	------	--------------	------	------	-------	---------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

**Guy Goodwin**

Island Location PIN 42150 - 1918 Island D 101  
Kenora

**Sector:** Miscellaneous Communal  
**Ministry Office:** Kenora

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### ESCHERICHIA COLI

#### CofA/Permit Non-Compliance

August 16, 2010	200	cfu/100 ml	/mon	1 exceedance	1500	1500	Training/Procedure Change	Voluntary Abatement Program Underway
-----------------	-----	------------	------	--------------	------	------	---------------------------	--------------------------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

### SUSPENDED SOLIDS

#### CofA/Permit Non-Compliance

August 31, 2010 - September 30, 2010	15	mg/L	/mon	2 exceedances	16	22.2	Training/Procedure Change	Voluntary Abatement Program Underway
---	----	------	------	---------------	----	------	---------------------------	--------------------------------------

**Total CofA/Permit Non-Compliance = 2 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Hastings and Prince Edward District School Board

1247 Old Highway 2  
Quinte West

**Sector:** Miscellaneous Communal  
**Ministry Office:** Peterborough

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>PHOSPHORUS</b>								
<b>Policy/Guideline Non-Conformance</b>								
January 1, 2010 - January 31, 2010	1	mg/L	mon avg	1 exceedance	1.63	1.63	Additional Monitoring Underway, Other	Assessment Underway
February 1, 2010 - February 28, 2010	1	mg/L	mon avg	1 exceedance	1.86	1.86	Additional Monitoring Underway, Other	Assessment Underway
March 1, 2010 - March 31, 2010	1	mg/L	mon avg	1 exceedance	1.55	1.55	Additional Monitoring Underway, Other	Assessment Underway
April 1, 2010 - April 30, 2010	1	mg/L	mon avg	1 exceedance	2.15	2.15	Additional Monitoring Underway, Other	Assessment Underway
May 1, 2010 - May 31, 2010	1	mg/L	mon avg	1 exceedance	2.31	2.31	Additional Monitoring Underway, Other	Assessment Underway
June 1, 2010 - June 30, 2010	1	mg/L	mon avg	1 exceedance	1.79	1.79	Additional Monitoring Underway, Other	Assessment Underway
July 1, 2010 - July 31, 2010	1	mg/L	mon avg	1 exceedance	1.78	1.78	Additional Monitoring Underway, Other	Assessment Underway
August 1, 2010 - August 31, 2010	1	mg/L	mon avg	1 exceedance	3	3	Additional Monitoring Underway, Other	Assessment Underway

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Hastings and Prince Edward District School Board

1247 Old Highway 2  
Quinte West

**Sector:** Miscellaneous Communal  
**Ministry Office:** Peterborough

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
September 1, 2010 - September 30, 2010	1	mg/L	mon avg	1 exceedance	2	2	Additional Monitoring Underway, Other	Assessment Underway
October 1, 2010 - October 31, 2010	1	mg/L	mon avg	1 exceedance	3.83	3.83	Additional Monitoring Underway, Other	Assessment Underway
November 1, 2010 - November 30, 2010	1	mg/L	mon avg	1 exceedance	3.66	3.66	Additional Monitoring Underway, Other	Assessment Underway
December 1, 2010 - December 31, 2010	1	mg/L	mon avg	1 exceedance	1.59	1.59	Additional Monitoring Underway, Other	Assessment Underway

**Total Policy/Guideline Non-Conformance = 12 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Husky Oil Limited

46 - 4040 Essex Rd  
Tecumseh

**Sector:** Miscellaneous Communal  
**Ministry Office:** Windsor

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>PHOSPHORUS</b>								
<b>CofA/Permit Non-Compliance</b>								
January 1, 2010 - January 31, 2010	0.5	mg/L	mon avg	1 exceedance	0.56	0.56	Equipment Modified - Repaired - Replaced or Re- calibrated	Voluntary Abatement Program Underway
November 1, 2010 - November 30, 2010	0.5	mg/L	mon avg	1 exceedance	0.52	0.52	Operational Process Modification	Assessment Complete - Incident Resolved

**Total CofA/Permit Non-Compliance = 2 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Husky Oil Operations Limited

21856 Old Highway # 2 Bainsville  
South Glengarry

**Sector:** Miscellaneous Communal  
**Ministry Office:** Cornwall

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### PHOSPHORUS

#### CofA/Permit Non-Compliance

January 1, 2010 - January 31, 2010	1	mg/L	mon avg	1 exceedance	1.39	1.39	Conducting Study	Assessment Underway
February 1, 2010 - February 28, 2010	1	mg/L	mon avg	1 exceedance	1.87	1.87	Conducting Study	Assessment Underway
March 1, 2010 - March 31, 2010	1	mg/L	mon avg	1 exceedance	1.5	1.5	Conducting Study	Assessment Underway
May 1, 2010 - May 31, 2010	1	mg/L	mon avg	1 exceedance	3.4	3.4	Conducting Study	Assessment Underway
August 1, 2010 - August 31, 2010	1	mg/L	mon avg	1 exceedance	1.56	1.56	Other	Assessment Underway

**Total CofA/Permit Non-Compliance = 5 exceedances**

### SUSPENDED SOLIDS

#### CofA/Permit Non-Compliance

January 1, 2010 - January 31, 2010	25	mg/L	mon avg	1 exceedance	32	32	Conducting Study	Assessment Underway
April 1, 2010 - April 30, 2010	25	mg/L	mon avg	1 exceedance	40	40	Conducting Study	Assessment Underway
July 1, 2010 - July 31, 2010	25	mg/L	mon avg	1 exceedance	26.5	48	Ceased Operations	Assessment Complete - No Action Required
August 1, 2010 - August 31, 2010	25	mg/L	mon avg	1 exceedance	93	93	Other	Assessment Underway

**Total CofA/Permit Non-Compliance = 4 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Lake Avenue Resort Park Inc.

Part Lot 17, Conc. 1, South Site of East Lake, To  
Prince Edward County

**Sector:** Miscellaneous Communal  
**Ministry Office:** Belleville

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>SUSPENDED SOLIDS</b>								
<b>CofA/Permit Non-Compliance</b>								
October 1, 2010 - October 31, 2010	10	mg/L	/mon	1 exceedance	119	119	Other	Assessment Complete - Incident Resolved

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Leeds Condominium Corporation #7

Lot: 5, Concession: 1  
Elizabethtown-Kitley

**Sector:** Miscellaneous Communal  
**Ministry Office:** Kingston

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>PHOSPHORUS</b>								
<b>CofA/Permit Non-Compliance</b>								
November 1, 2010 - November 30, 2010	1	mg/L	mon avg	1 exceedance	2.1	2.1	Equipment Modified - Repaired - Replaced or Re- calibrated, Other	Assessment Complete - No Action Required
December 1, 2010 - December 31, 2010	1	mg/L	mon avg	1 exceedance	1.8	1.8	Equipment Modified - Repaired - Replaced or Re- calibrated	Assessment Complete - Incident Resolved

**Total CofA/Permit Non-Compliance = 2 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Mini Lakes Residents Association - Puslinch

34 - 7541 Wellington County Rd  
Puslinch

**Sector:** Miscellaneous Communal  
**Ministry Office:** Guelph

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### NITRATE

##### CofA/Permit Non-Compliance

December 31, 2010	5	mg/L	rolling avg	1 exceedance	5.1	5.1	Conducting Study	Assessment Underway
-------------------	---	------	-------------	--------------	-----	-----	------------------	---------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Mishar Holdings Inc.

72 Main St W Lyn  
Elizabethtown-Kitley

**Sector:** Miscellaneous Communal  
**Ministry Office:** Kingston

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### CARBONACEOUS BIOCHEMICAL OXYGEN DEMAND

#### CofA/Permit Non-Compliance

April 22, 2010	15	mg/L	/d	1 exceedance	110	110	Conducting Study	Assessment Underway
----------------	----	------	----	--------------	-----	-----	------------------	---------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

### NITRATE

#### CofA/Permit Non-Compliance

March 01, 2010	2.5	mg/L	/d	1 exceedance	24.3	24.3	Conducting Study	Assessment Underway
----------------	-----	------	----	--------------	------	------	------------------	---------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

### SUSPENDED SOLIDS

#### CofA/Permit Non-Compliance

April 22, 2010	15	mg/L	/d	1 exceedance	96	96	Conducting Study	Assessment Underway
----------------	----	------	----	--------------	----	----	------------------	---------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### New Reinland Mennonite Church of Ontario

1330 Mersea Road 6  
Leamington

**Sector:** Miscellaneous Communal  
**Ministry Office:** Windsor

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### CARBONACEOUS BIOCHEMICAL OXYGEN DEMAND

#### CofA/Permit Non-Compliance

July 1, 2010 - July 31, 2010	10	mg/L	mon avg	1 exceedance	12	12	Other	Voluntary Abatement Program Underway
---------------------------------	----	------	---------	--------------	----	----	-------	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

### SUSPENDED SOLIDS

#### CofA/Permit Non-Compliance

January 1, 2010 - January 31, 2010	10	mg/L	mon avg	1 exceedance	22.5	22.5	Other	Voluntary Abatement Program Underway
February 1, 2010 - February 28, 2010	10	mg/L	mon avg	1 exceedance	10.5	10.5	Other	Voluntary Abatement Program Underway
March 1, 2010 - March 31, 2010	10	mg/L	mon avg	1 exceedance	12.5	12.5	Other	Voluntary Abatement Program Underway
April 1, 2010 - April 30, 2010	10	mg/L	mon avg	1 exceedance	15.5	15.5	Other	Voluntary Abatement Program Underway
July 1, 2010 - July 31, 2010	10	mg/L	mon avg	1 exceedance	12.5	12.5	Other	Voluntary Abatement Program Underway

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### New Reinland Mennonite Church of Ontario

1330 Mersea Road 6  
Leamington

**Sector:** Miscellaneous Communal  
**Ministry Office:** Windsor

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
September 1, 2010 - September 30, 2010	10	mg/L	mon avg	1 exceedance	23.5	23.5	Other	Voluntary Abatement Program Underway

**Total CofA/Permit Non-Compliance = 6 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### North Bay Psychiatric Hospital

4700 Highway 11 N  
North Bay

**Sector:** Miscellaneous Communal  
**Ministry Office:** North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### HIGH PH EFFLUENT

#### CofA/Permit Non-Compliance

September 04, 2010	9.5	pH	any	1 exceedance	9.8	9.8	Operational Process Modification	Assessment Complete - No Action Required
--------------------	-----	----	-----	--------------	-----	-----	----------------------------------	--

**Total CofA/Permit Non-Compliance = 1 exceedance**

### LOW PH EFFLUENT

#### CofA/Permit Non-Compliance

May 03, 2010	6	pH	any	1 exceedance	4.85	4.85	Additional Monitoring Underway	Assessment Complete - No Action Required
--------------	---	----	-----	--------------	------	------	--------------------------------	--

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Oslerbrook Golf & Country Club Inc.

2634 Conc 10  
Collingwood

**Sector:** Miscellaneous Communal  
**Ministry Office:** Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>ESCHERICHIA COLI</b>								
<b>CofA/Permit Non-Compliance</b>								
July 1, 2010 - July 31, 2010	100	cfu/100 ml	mon avg	1 exceedance	238	238	Equipment Modified - Repaired - Replaced or Re- calibrated	Voluntary Abatement Program Underway

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Petro-Canada

Lot: 17, 18, Con 5 Loyalist Township  
Loyalist

**Sector:** Miscellaneous Communal  
**Ministry Office:** Kingston

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### PHOSPHORUS

#### CofA/Permit Non-Compliance

February 1, 2010 - February 28, 2010	0.5	mg/L	/mon	1 exceedance	0.62	0.62	Equipment Modified - Repaired - Replaced or Re- calibrated	Assessment Complete - Incident Resolved
March 1, 2010 - March 31, 2010	0.5	mg/L	mon avg	1 exceedance	0.63	0.63	Other	Assessment Complete - No Action Required

**Total CofA/Permit Non-Compliance = 2 exceedances**

### TOTAL AMMONIA NITROGEN

#### CofA/Permit Non-Compliance

February 1, 2010 - February 28, 2010	8	mg/L	/mon	1 exceedance	28.18	28.18	Equipment Modified - Repaired - Replaced or Re- calibrated	Assessment Complete - Incident Resolved
March 1, 2010 - March 31, 2010	8	mg/L	mon avg	1 exceedance	45.3	45.3	Other	Assessment Complete - No Action Required

**Total CofA/Permit Non-Compliance = 2 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Piper's Heath Golf Club Ltd.

5527 Trafalgar Rd  
Milton

**Sector:** Miscellaneous Communal  
**Ministry Office:** Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### ESCHERICHIA COLI

#### CofA/Permit Non-Compliance

February 1, 2010 - February 28, 2010	100	cfu/100 ml	mon avg	1 exceedance	537	537	Conducting Study	Assessment Underway
March 1, 2010 - March 31, 2010	100	cfu/100 ml	mon avg	1 exceedance	239	239	Conducting Study	Assessment Underway

**Total CofA/Permit Non-Compliance = 2 exceedances**

### PHOSPHORUS

#### CofA/Permit Non-Compliance

January 1, 2010 - January 31, 2010	2.5	mg/L	mon avg	1 exceedance	6.2	6.2	Other	Assessment Underway
---------------------------------------	-----	------	---------	--------------	-----	-----	-------	---------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

### SUSPENDED SOLIDS

#### CofA/Permit Non-Compliance

January 1, 2010 - January 31, 2010	15	mg/L	mon avg	1 exceedance	97	97	Other	Assessment Underway
March 1, 2010 - March 31, 2010	15	mg/L	mon avg	1 exceedance	20	20	Conducting Study	Assessment Underway

**Total CofA/Permit Non-Compliance = 2 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

**Rice Development Corp.**

8006 - 8010 Yonge St  
Innisfil

**Sector:** Miscellaneous Communal  
**Ministry Office:** Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>NITRATES</b>								
<b>CofA/Permit Non-Compliance</b>								
September 20, 2010	2.5	mg/L	mon avg	1 exceedance	5.4	5.4	Operational Process Modification	Voluntary Abatement Program Underway

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Seaway Valley Food & Travel Centre Inc.

2690 Brookdale Ave  
Cornwall

**Sector:** Miscellaneous Communal  
**Ministry Office:** Cornwall

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>TOTAL AMMONIA NITROGEN</b>								
<b>CofA/Permit Non-Compliance</b>								
June 1, 2010 - June 30, 2010	2	mg/L	mon avg	1 exceedance	8.11	8.11	Other	Assessment Complete - No Action Required
August 1, 2010 - August 31, 2010	2	mg/L	mon avg	1 exceedance	2.98	2.98	Conducting Study	Assessment Underway
<b>Total CofA/Permit Non-Compliance = 2 exceedances</b>								

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Sudbury Condominium Corporation #5

Part of 13, Concession: 2  
Curtin

**Sector:** Miscellaneous Communal  
**Ministry Office:** Sudbury

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### SUSPENDED SOLIDS

##### Policy/Guideline Non-Conformance

January 1, 2010 - December 31, 2010	25	mg/L	annual avg	1 exceedance	39.8	39.8	Operational process modification	Voluntary Abatement Program Underway
--	----	------	------------	--------------	------	------	-------------------------------------	---

**Total Policy/Guideline Non-Conformance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Suncor Energy Products Partnership

Lot 6 Concession 01  
Innisfil

**Sector:** Miscellaneous Communal  
**Ministry Office:** Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### PHOSPHORUS

#### CofA/Permit Non-Compliance

November 1, 2010 - November 30, 2010	0.3	mg/L	mon avg	1 exceedance	0.5	0.5	Equipment Modified - Repaired - Replaced or Re- calibrated	Assessment Complete - No Action Required
---	-----	------	---------	--------------	-----	-----	--	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

### TOTAL AMMONIA NITROGEN

#### CofA/Permit Non-Compliance

December 1, 2010 - December 31, 2010	2.5	mg/L	mon avg	1 exceedance	3.5	3.5	Other	Assessment Complete - No Action Required
---	-----	------	---------	--------------	-----	-----	-------	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Team Aquatic Management Inc.

4791 Hwy 28 Burleigh Falls  
North Kawartha

**Sector:** Miscellaneous Communal  
**Ministry Office:** Peterborough

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>PHOSPHORUS</b>								
<b>CofA/Permit Non-Compliance</b>								
June 1, 2010 - June 30, 2010	0.3	mg/L	mon avg	1 exceedance	0.34	0.34	Equipment Modified - Repaired - Replaced or Re- calibrated, New Equipment or Treatment Process Installed	Assessment Complete - Incident Resolved

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Terra International (Canada) Inc.

161 Bickford Line Courtright  
St. Clair

**Sector:**

Miscellaneous Communal

**Ministry Office:** Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### PHOSPHORUS

#### CofA/Permit Non-Compliance

January 1, 2010 - January 31, 2010	0.04	kg/d	mon avg	1 exceedance	0.05	0.05	Operational Process Modification	Provincial Officer's Order Issued
January 1, 2010 - January 31, 2010	1	mg/L	mon avg	1 exceedance	2.16	2.16	Operational Process Modification	Provincial Officer's Order Issued

**Total CofA/Permit Non-Compliance = 2 exceedances**

### SUSPENDED SOLIDS

#### CofA/Permit Non-Compliance

January 1, 2010 - January 31, 2010	25	mg/L	mon avg	3 exceedances	27.25	47.3	Operational Process Modification	Provincial Officer's Order Issued
May 1, 2010 - November 30, 2010	0.95	kg/d	mon avg	2 exceedances	1.11	1.11	Operational Process Modification	Provincial Officer's Order Issued

**Total CofA/Permit Non-Compliance = 5 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

**The Brockville Society of the  
Standard Church of  
America/Weslayan Church of  
Canada**

3545 County Road No. 27 R. R. 2, Lyn  
Elizabethtown-Kitley

**Sector:** Miscellaneous Communal  
**Ministry Office:** Kingston

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### **CARBONACEOUS BIOCHEMICAL OXYGEN DEMAND**

#### **CofA/Permit Non-Compliance**

December 01, 2010	10	mg/L	/d	1 exceedance	14	14	Additional Monitoring Underway	Other Abatement Action Taken
-------------------	----	------	----	--------------	----	----	--------------------------------	------------------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

### **SUSPENDED SOLIDS**

#### **CofA/Permit Non-Compliance**

December 01, 2010	10	mg/L	/d	1 exceedance	14	188	Additional Monitoring Underway	Other Abatement Action Taken
-------------------	----	------	----	--------------	----	-----	--------------------------------	------------------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of Haldimand County - Caledonia WPCP

320 Lanark St Caledonia  
Haldimand

**Sector:** Municipal Sewage  
**Ministry Office:** Hamilton

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### ESCHERICHIA COLI

#### CofA/Permit Non-Compliance

April 1, 2010 - April 30, 2010	200	cfu/100 ml	mon avg. on a geo. mean density	1 exceedance	409	409	Conducting Study	Assessment Underway
-----------------------------------	-----	---------------	--	--------------	-----	-----	------------------	---------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

### TOTAL AMMONIA NITROGEN

#### CofA/Permit Non-Compliance

February 1, 2010 - February 28, 2010	2	mg/L	mon avg	1 exceedance	3.03	3.03	Equipment Modified - Repaired - Replaced or Re- calibrated, Operational Process Modification, Training/Procedure Change	Assessment Underway
May 1, 2010 - May 31, 2010	1	mg/L	mon avg	1 exceedance	6.7	6.7	Additional Monitoring Underway	Assessment Underway

**Total CofA/Permit Non-Compliance = 2 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of Loyalist Township

Taylor Kid Road (Lot 37, Concession 1)  
Loyalist Township

**Sector:** Municipal Sewage  
**Ministry Office:** Kingston

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### HIGH PH EFFLUENT

#### CofA/Permit Non-Compliance

January 1, 2010 - December 31, 2010	9.5	pH	any	107 exceedances	9.52	10.66	Other	Assessment Underway
--	-----	----	-----	-----------------	------	-------	-------	---------------------

**Total CofA/Permit Non-Compliance = 107 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

**The Corporation of the City of  
Brockville**

1807 County Road 2 East  
Brockville

**Sector:** Municipal Sewage  
**Ministry Office:** Kingston

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>BIOCHEMICAL OXYGEN DEMAND</b>								
<b>CofA/Permit Non-Compliance</b>								
January 1, 2010 - December 31, 2010	35	mg/L	annual avg	1 exceedance	53.28	53.28	Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway
January 1, 2010 - December 31, 2010	763	kg/d	annual avg	1 exceedance	942.37	942.37	Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway

**Total CofA/Permit Non-Compliance = 2 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the City of Kawartha Lakes - Kings Bay Development

233 Southcrest Drive, Mariposa Twp  
Kawartha Lakes

**Sector:** Municipal Sewage  
**Ministry Office:** Peterborough

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### PHOSPHORUS

##### CofA/Permit Non-Compliance

January 1, 2010 - December 31, 2010	1	mg/L	annual avg	1 exceedance	1.29	1.29	Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway
--	---	------	------------	--------------	------	------	--	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the City of Kawartha Lakes - Lindsay Wastewater Treatment Plant

48 Lagoon Road, Lindsay  
Kawartha Lakes

**Sector:** Municipal Sewage  
**Ministry Office:** Peterborough

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>NITRATE + NITRITE</b>								
<b>CofA/Permit Non-Compliance</b>								
February 1, 2010 - February 28, 2010	3	mg/L	mon avg	1 exceedance	5.05	5.05	Equipment Modified - Repaired - Replaced or Re- calibrated	Assessment Complete - No Action Required
February 1, 2010 - February 28, 2010	64.5	kg/d	mon avg	1 exceedance	73.69	73.69	Equipment Modified - Repaired - Replaced or Re- calibrated	Assessment Complete - No Action Required

**Total CofA/Permit Non-Compliance = 2 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the City of Kenora - Kenora Wastewater Treatment Plant

18 Sewage Plant Rd  
Kenora

**Sector:** Municipal Sewage  
**Ministry Office:** Kenora

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>ESCHERICHIA COLI</b>								
<b>CofA/Permit Non-Compliance</b>								
March 1, 2010 - March 31, 2010	200	cfu/100 ml	mon avg. on a geo. mean density	1 exceedance	232	232	Additional Monitoring Underway, Equipment Modified - Repaired - Replaced or Re-calibrated, Operational Process Modification	Assessment Complete - Incident Resolved

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the City of London - Southland WPCP

Dennis Ave  
London

**Sector:** Municipal Sewage  
**Ministry Office:** London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>TOTAL AMMONIA NITROGEN</b>								
<b>CofA/Permit Non-Compliance</b>								
July 1, 2010 - July 31, 2010	3	mg/L	/mon	1 exceedance	4.4	4.4	Other	Other Abatement Action Taken

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the City of North Bay - North Bay Sewage Treatment Plant

650 Memorial Dr  
North Bay

**Sector:** Municipal Sewage  
**Ministry Office:** North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### PHOSPHORUS

##### Policy/Guideline Non-Conformance

December 1, 2010 - December 31, 2010	1	mg/L	mon avg	1 exceedance	1.14	1.14	New Equipment or Treatment Process Installed	Assessment Complete - Incident Resolved
---	---	------	---------	--------------	------	------	---	--

**Total Policy/Guideline Non-Conformance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the City of Owen Sound - Owen Sound Wastewater Treatment Plant

2050 Third Ave E  
Owen Sound

**Sector:** Municipal Sewage  
**Ministry Office:** Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### PHOSPHORUS

##### CofA/Permit Non-Compliance

February 1, 2010 - February 28, 2010	1	mg/L	mon avg	1 exceedance	1.13	1.13	Additional Monitoring Underway	Assessment Complete - Incident Resolved
---	---	------	---------	--------------	------	------	-----------------------------------	--

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the City of Pembroke

98 Rankin St  
Pembroke

**Sector:** Municipal Sewage  
**Ministry Office:** Ottawa

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>ESCHERICHIA COLI</b>								
<b>CofA/Permit Non-Compliance</b>								
January 1, 2010 - December 31, 2010	200	CT/100 mL	mon avg	4 exceedances	468	736	Additional Monitoring Underway, Conducting Study	Voluntary Abatement Program Underway

**Total CofA/Permit Non-Compliance = 4 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

**The Corporation of the City of  
Quinte West**

1378 Trenton-Frankford Rd  
Quinte West

**Sector:** Municipal Sewage  
**Ministry Office:** Peterborough

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### ESCHERICHIA COLI

#### CofA/Permit Non-Compliance

January 1, 2010 - January 31, 2010	200	cfu/100 ml	mon avg	1 exceedance	889.5	889.5	Operational Process Modification	Other Abatement Action Taken
---------------------------------------	-----	---------------	---------	--------------	-------	-------	-------------------------------------	------------------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

### SUSPENDED SOLIDS

#### CofA/Permit Non-Compliance

January 1, 2010 - January 31, 2010	25	mg/L	mon avg	1 exceedance	29.4	29.4	Operational Process Modification	Other Abatement Action Taken
---------------------------------------	----	------	---------	--------------	------	------	-------------------------------------	------------------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the City of Sarnia - Brights Grove Lagoons

255 North Christina St Old Lakeshore Rd.  
Sarnia

**Sector:** Municipal Sewage  
**Ministry Office:** Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### BIOCHEMICAL OXYGEN DEMAND

#### CofA/Permit Non-Compliance

November 1, 2010 - November 30, 2010	10	mg/L	/mon	1 exceedance	10.5	10.5	Ceased Operations	Other Abatement Action Taken
---	----	------	------	--------------	------	------	-------------------	------------------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

### SUSPENDED SOLIDS

#### CofA/Permit Non-Compliance

November 1, 2010 - November 30, 2010	10	mg/L	/mon	1 exceedance	18.5	18.5	Ceased Operations	Other Abatement Action Taken
---	----	------	------	--------------	------	------	-------------------	------------------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the City of Temiskaming Shores - North Cobalt Lagoon

Lakeview Drive  
Haileybury

**Sector:** Municipal Sewage  
**Ministry Office:** North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### BIOCHEMICAL OXYGEN DEMAND

##### CofA/Permit Non-Compliance

November 1, 2010 - November 30, 2010	25	mg/L	mon avg	1 exceedance	28.6	28.6	Other	Assessment Complete - No Action Required
---	----	------	---------	--------------	------	------	-------	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the County of Prince Edward - Wellington Water Pollution Control Plant

460 Wellington Main St  
Prince Edward

**Sector:** Municipal Sewage  
**Ministry Office:** Belleville

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### SUSPENDED SOLIDS

##### CofA/Permit Non-Compliance

May 1, 2010 - May 31, 2010	25	mg/L	mon avg	1 exceedance	28	28	Other	Assessment Complete - Incident Resolved
-------------------------------	----	------	---------	--------------	----	----	-------	--

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Municipality of Arran-Elderslie - Chesley Sewage Works

Lot: 27 & 28, Concession: 2  
Arran-Elderslie

**Sector:** Municipal Sewage  
**Ministry Office:** Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>HYDROGEN SULPHIDE</b>								
<b>CofA/Permit Non-Compliance</b>								
January 1, 2010 - December 31, 2010	0	mg/L	annual avg	1 exceedance	0.3	0.3	Equipment Modified - Repaired - Replaced or Re- calibrated	Assessment Complete - Incident Resolved

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Municipality of Arran-Elderslie - Paisley Sewage Treatment Plant

322 George St N  
Arran-Elderslie

**Sector:** Municipal Sewage  
**Ministry Office:** Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>ESCHERICHIA COLI</b>								
<b>CofA/Permit Non-Compliance</b>								
June 1, 2010 - June 30, 2010	200	cfu/100 ml	mon avg. on a geo. mean density	1 exceedance	237	237	Operational Process Modification	Assessment Complete - No Action Required

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

**The Corporation of the  
Municipality of Brighton**

100 County Road 64  
Brighton

**Sector:** Municipal Sewage  
**Ministry Office:** Peterborough

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>TOTAL AMMONIA NITROGEN</b>								
<b>CofA/Permit Non-Compliance</b>								
June 1, 2010 - June 30, 2010	14	mg/L	mon avg	1 exceedance	22.56	22.56	Other	Assessment Underway
July 1, 2010 - July 31, 2010	14	mg/L	mon avg	1 exceedance	16.93	16.93	Additional Monitoring Underway, Conducting Study	Assessment Underway
August 1, 2010 - August 31, 2010	14	mg/L	mon avg	1 exceedance	15.95	15.95	Additional Monitoring Underway, Conducting Study, New Equipment or Treatment Process Installed	Assessment Underway
September 1, 2010 - September 30, 2010	14	mg/L	mon avg	1 exceedance	16.7	16.7	Additional Monitoring Underway, Conducting Study, New Equipment or Treatment Process Installed	Assessment Underway
October 1, 2010 - October 31, 2010	14	mg/L	mon avg	1 exceedance	17.3	17.3	Additional Monitoring Underway, Conducting Study, New Equipment or Treatment Process Installed	Assessment Underway
November 1, 2010 - November 30, 2010	17	mg/L	mon avg	1 exceedance	20.2	20.2	Additional Monitoring Underway, Conducting Study, New Equipment or Treatment Process Installed	Assessment Underway

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

---

**The Corporation of the  
Municipality of Brighton**

100 County Road 64  
Brighton

**Sector:** Municipal Sewage  
**Ministry Office:** Peterborough

---

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
Total CofA/Permit Non-Compliance = 6 exceedances								

---

---

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Municipality of Huron East - Seaforth Sewage Treatment Plant

79468 Hannah Line  
Huron East

**Sector:** Municipal Sewage  
**Ministry Office:** Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>TOTAL AMMONIA NITROGEN</b>								
<b>CofA/Permit Non-Compliance</b>								
March 22, 2010	6	mg/L	/d	1 exceedance	7.8	7.8	Additional Monitoring Underway, Other	Assessment Underway

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Municipality of Kincardine - Kincardine Wastewater Treatment Plant

520 Bruce Ave  
Kincardine

**Sector:** Municipal Sewage  
**Ministry Office:** Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>SUSPENDED SOLIDS</b>								
<b>CofA/Permit Non-Compliance</b>								
July 1, 2010 - July 31, 2010	40	mg/L	mon avg	1 exceedance	51	51	Conducting Study	Assessment Underway
August 1, 2010 - August 31, 2010	40	mg/L	mon avg	1 exceedance	41.3	41.3	Additional Monitoring Underway	Assessment Complete - No Action Required
<b>Total CofA/Permit Non-Compliance = 2 exceedances</b>								

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Municipality of Leamington - Leamington Pollution Control Centre

435 Seacliff Dr E  
Leamington

**Sector:** Municipal Sewage  
**Ministry Office:** Windsor

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### SUSPENDED SOLIDS

##### CofA/Permit Non-Compliance

September 1, 2010 - September 30, 2010	15	mg/L	mon avg	1 exceedance	16.9	16.9	Other	Assessment Complete - Incident Resolved
---	----	------	---------	--------------	------	------	-------	--

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Municipality of Marmora and Lake

Village of Deloro  
Marmora and Lake

**Sector:** Municipal Sewage  
**Ministry Office:** Belleville

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>PHOSPHORUS (N.O.S.)</b>								
<b>Policy/Guideline Non-Conformance</b>								
January 1, 2010 - December 31, 2010	1	mg/l	mon avg	12 exceedances	1.5	2.11	Conducting Study	Voluntary Abatement Program Underway

**Total Policy/Guideline Non-Conformance = 12 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Municipality of Oliver Paipoonge - King George's Park

Lot 2, 3, 4, 5 Conc A, B  
Oliver Paipoonge

**Sector:** Miscellaneous Communal  
**Ministry Office:** Thunder Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>SUSPENDED SOLIDS</b>								
<b>CofA/Permit Non-Compliance</b>								
November 04, 2010	25	mg/L	/d	1 exceedance	31.6	31.6	New Equipment or Treatment Process Installed	Assessment Complete - Incident Resolved

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Municipality of Red Lake - Cochenour Sewage Lagoon

Highway 125 Mining Claim KRL 7462  
Red Lake

**Sector:** Municipal Sewage  
**Ministry Office:** Kenora

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>SUSPENDED SOLIDS</b>								
<b>CofA/Permit Non-Compliance</b>								
October 1, 2010 - October 31, 2010	25	mg/L	mon avg	1 exceedance	50.3	50.3	Action Plan Submitted - Implementing Improvements, Equipment Modified - Repaired - Replaced or Re- calibrated	Voluntary Abatement Program Underway

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Municipality of Sioux Lookout - Sioux Lookout Pollution Control Plant

159 King St W  
Sioux Lookout

**Sector:** Municipal Sewage  
**Ministry Office:** Kenora

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>ESCHERICHIA COLI</b>								
<b>CofA/Permit Non-Compliance</b>								
March 1, 2010 - March 31, 2010	200	cfu/100 ml	mon avg	1 exceedance	605	605	Equipment Modified - Repaired - Replaced or Re- calibrated, Other	Assessment Complete - Incident Resolved

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Municipality of Strathroy- Caradoc - Strathroy Sewage Treatment Plant

27886 Pike Rd  
Adelaide Metcalfe

**Sector:** Municipal Sewage  
**Ministry Office:** London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>TOTAL AMMONIA NITROGEN</b>								
<b>CofA/Permit Non-Compliance</b>								
December 1, 2010 - December 31, 2010	5	mg/L	mon avg	1 exceedance	13.43	13.43	Additional Monitoring Underway, Operational Process Modification	Assessment Complete - Incident Resolved

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Municipality of Trent Hills

Lot 18, Conc 3, Geographic Twp of Percy  
Trent Hills

**Sector:** Municipal Sewage  
**Ministry Office:** Peterborough

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### AMMONIA

#### CofA/Permit Non-Compliance

April 13, 2010 - June 5, 2010	3	mg/L	seasonal avg	1 exceedance	4.04	4.04	Other	Assessment Underway
November 25, 2010 - December 22, 2010	3	mg/L	seasonal avg	1 exceedance	4.6	4.6	Other	Assessment Underway

**Total CofA/Permit Non-Compliance = 2 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Municipality of West Nipissing - Field Sewage Treatment Plant

110 Morion Street, Field  
West Nipissing

**Sector:** Municipal Sewage  
**Ministry Office:** North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### PHOSPHORUS

#### CofA/Permit Non-Compliance

January 1, 2010 - January 31, 2010	1	mg/L	mon avg	1 exceedance	4.6	4.6	Conducting Study	Assessment Underway
February 1, 2010 - February 28, 2010	1	mg/L	mon avg	1 exceedance	4.2	4.2	Conducting Study	Assessment Underway
May 1, 2010 - May 31, 2010	1	mg/L	mon avg	1 exceedance	1.63	1.63	Conducting Study	Assessment Underway
June 1, 2010 - June 30, 2010	1	mg/L	mon avg	1 exceedance	1.88	1.88	Conducting Study	Assessment Underway
July 1, 2010 - July 31, 2010	1	mg/L	mon avg	1 exceedance	1.39	1.39	Conducting Study	Assessment Underway

**Total CofA/Permit Non-Compliance = 5 exceedances**

### SUSPENDED SOLIDS

#### CofA/Permit Non-Compliance

March 1, 2010 - March 31, 2010	25	mg/L	mon avg	1 exceedance	50.3	50.3	Conducting Study	Assessment Underway
April 1, 2010 - April 30, 2010	25	mg/L	mon avg	1 exceedance	27.8	27.8	Conducting Study	Assessment Underway
May 1, 2010 - May 31, 2010	25	mg/L	mon avg	1 exceedance	29.3	29.3	Conducting Study	Assessment Underway
June 1, 2010 - June 30, 2010	25	mg/L	mon avg	1 exceedance	25.3	25.3	Conducting Study	Assessment Underway

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

---

### **The Corporation of the Municipality of West Nipissing - Field Sewage Treatment Plant**

110 Morion Street, Field  
West Nipissing

**Sector:** Municipal Sewage  
**Ministry Office:** North Bay

---

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
Total CofA/Permit Non-Compliance = 4 exceedances								

---

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of The Nation Municipality - Limoges Sewage Lagoon

1899 Route 500 West  
The Nation

**Sector:** Municipal Sewage  
**Ministry Office:** Cornwall

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### HYDROGEN SULPHIDE

##### CofA/Permit Non-Compliance

April 07, 2010	0.01	mg/L	any	1 exceedance	0.02	0.02	Action Plan Submitted - Implementing Improvements	Assessment Complete - Incident Resolved
----------------	------	------	-----	--------------	------	------	--	--

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of The Nation Municipality - St. Albert Sewage Lagoon

1665 Route 900 West  
The Nation

**Sector:** Municipal Sewage  
**Ministry Office:** Cornwall

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### SUSPENDED SOLIDS

##### CofA/Permit Non-Compliance

April 12, 2010	30	mg/L	seasonal avg	1 exceedance	33	33	Other	Assessment Complete - No Action Required
----------------	----	------	-----------------	--------------	----	----	-------	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Separated Town of Smiths Falls

180 Queen St South of Highway 43  
Smiths Falls

**Sector:** Municipal Sewage  
**Ministry Office:** Ottawa

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### PHOSPHORUS

#### CofA/Permit Non-Compliance, Policy/Guideline Non-Conformance

July 1, 2010 - July 31, 2010	0.3	mg/L	mon avg	1 exceedance	0.61	0.61	Equipment Modified - Repaired - Replaced or Re- calibrated, New Equipment or Treatment Process Installed	Voluntary Abatement Program Underway
---------------------------------	-----	------	---------	--------------	------	------	---	---

**Total CofA/Permit Non-Compliance, Policy/Guideline Non-Conformance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

**The Corporation of the Town of Aylmer**

9853 Rogers Rd  
Malahide

**Sector:** Municipal Sewage  
**Ministry Office:** London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### ESCHERICHIA COLI

#### CofA/Permit Non-Compliance

August 1, 2010 - August 31, 2010	200	CT/100 mL	mon avg. on a geo. mean density	1 exceedance	468	468	None Required	Assessment Complete - No Action Required
-------------------------------------	-----	--------------	--	--------------	-----	-----	---------------	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Town of Bancroft

88 Anderson Lane  
Bancroft

**Sector:** Municipal Sewage  
**Ministry Office:** Belleville

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### ESCHERICHIA COLI

#### CofA/Permit Non-Compliance

March 1, 2010 - March 31, 2010	150	cfu/100 ml	/mon	1 exceedance	296	296	New Equipment or Treatment Process Installed	Assessment Complete - Incident Resolved
-----------------------------------	-----	---------------	------	--------------	-----	-----	---	--

**Total CofA/Permit Non-Compliance = 1 exceedance**

### PHOSPHORUS

#### CofA/Permit Non-Compliance, Policy/Guideline Non-Conformance

June 1, 2010 - June 30, 2010	1	mg/L	/mon	1 exceedance	1.49	1.49	None Required	Assessment Complete - No Action Required
---------------------------------	---	------	------	--------------	------	------	---------------	---

**Total CofA/Permit Non-Compliance, Policy/Guideline Non-Conformance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Town of Cobalt - Cobalt Wetland

Hudson Bay Rd  
Cobalt

**Sector:** Municipal Sewage  
**Ministry Office:** North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### BIOCHEMICAL OXYGEN DEMAND

#### Order Non-Compliance

January 1, 2010 - January 31, 2010	25	mg/L	mon avg	1 exceedance	25.73	25.73	Conducting Study, New Equipment or Treatment Process Installed	Director's Order Issued
February 1, 2010 - February 28, 2010	25	mg/L	mon avg	1 exceedance	38.25	38.25	Conducting Study, New Equipment or Treatment Process Installed	Director's Order Issued

**Total Order Non-Compliance = 2 exceedances**

### SUSPENDED SOLIDS

#### Order Non-Compliance

July 1, 2010 - July 31, 2010	242	kg	/mon	1 exceedance	411.7	411.7	New Equipment or Treatment Process Installed, Other	Director's Order Issued
July 1, 2010 - July 31, 2010	25	mg/L	mon avg	1 exceedance	34.6	34.6	Other	Director's Order Issued

**Total Order Non-Compliance = 2 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Town of Deep River

1 Cedar Rd  
Deep River

**Sector:** Municipal Sewage  
**Ministry Office:** Ottawa

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### PHOSPHORUS

#### CofA/Permit Non-Compliance

December 1, 2010 - December 31, 2010	1	mg/L	/mon	1 exceedance	1.13	1.13	Equipment Modified - Repaired - Replaced or Re- calibrated	Assessment Complete - No Action Required
---	---	------	------	--------------	------	------	--	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Town of Englehart

First Street, Englehart  
North Bay

**Sector:** Municipal Sewage  
**Ministry Office:** North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>HIGH PH EFFLUENT</b>								
<b>CofA/Permit Non-Compliance</b>								
May 03, 2010	9	pH	mon avg	1 exceedance	9.08	9.08	None Required	Assessment Complete - No Action Required

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

**The Corporation of the Town of  
Hanover**

718 7th Ave  
Hanover

**Sector:** Municipal Sewage  
**Ministry Office:** Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>PHOSPHORUS</b>								
<b>CofA/Permit Non-Compliance</b>								
November 1, 2010 - November 30, 2010	1	mg/L	mon avg	1 exceedance	1.11	1.11	Equipment Modified - Repaired - Replaced or Re- calibrated	Assessment Complete - Incident Resolved

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Town of Iroquois Falls - Iroquois Falls Sewage Treatment Plant

2 Northwest Industrial Rd  
Iroquois Falls

**Sector:** Municipal Sewage  
**Ministry Office:** Timmins

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### SUSPENDED SOLIDS

##### CofA/Permit Non-Compliance

November 1, 2010 - November 30, 2010	25	mg/L	/mon	1 exceedance	33.2	33.2	none required	Assessment Complete - No Action Required
---	----	------	------	--------------	------	------	---------------	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Town of New Tecumseth

Lot 6 Concession 13  
New Tecumseth

**Sector:** Municipal Sewage  
**Ministry Office:** Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>TOTAL AMMONIA NITROGEN</b>								
<b>CofA/Permit Non-Compliance</b>								
April 1, 2010 - April 30, 2010	3.3	mg/L	mon avg	1 exceedance	5.3	5.3	Operational Process Modification	Assessment Complete - Incident Resolved
May 1, 2010 - May 31, 2010	0.3	mg/L	mon avg	1 exceedance	2.1	2.1	Conducting Study	Voluntary Abatement Program Underway

**Total CofA/Permit Non-Compliance = 2 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Town of Smooth Rock Falls - Smooth Rock Falls Sewage Treatment Plant

110 First St  
Smooth Rock Falls

**Sector:** Municipal Sewage  
**Ministry Office:** Timmins

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>ESCHERICHIA COLI</b>								
<b>CofA/Permit Non-Compliance</b>								
April 1, 2010 - April 30, 2010	200	cfu/100 ml	mon avg. on a geo. mean density	1 exceedance	386.196	386.196	New Equipment or Treatment Process Installed	Voluntary Abatement Program Underway
July 1, 2010 - July 31, 2010	200	cfu/100 ml	mon avg. on a geo. mean density	1 exceedance	4993.703	4993.703	New Equipment or Treatment Process Installed	Assessment Complete - Incident Resolved
October 1, 2010 - October 31, 2010	200	cfu/100 ml	mon avg. on a geo. mean density	1 exceedance	1289.483	1289.483	None Required	Assessment Complete - No Action Required
November 1, 2010 - November 30, 2010	200	cfu/100 ml	mon avg. on a geo. mean density	1 exceedance	273.129	273.129	Other	Voluntary Abatement Program Underway

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Town of Smooth Rock Falls - Smooth Rock Falls Sewage Treatment Plant

110 First St  
Smooth Rock Falls

**Sector:** Municipal Sewage  
**Ministry Office:** Timmins

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
December 1, 2010 - December 31, 2010	200	cfu/100 ml	mon avg. on a geo. mean density	1 exceedance	254.754	254.754	Other	Voluntary Abatement Program Underway

**Total CofA/Permit Non-Compliance = 5 exceedances**

### RESIDUAL CHLORINE

#### CofA/Permit Non-Compliance

September 1, 2010 - September 30, 2010	0.02	mg/L	/mon	1 exceedance	0.33	0.33	None Required	Assessment Complete - No Action Required
---	------	------	------	--------------	------	------	---------------	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Town of Tecumseh - Skyway Subdivision Wastewater Treatment Facility

McCord Lane  
Tecumseh

**Sector:** Municipal Sewage  
**Ministry Office:** Windsor

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### PHOSPHORUS

##### CofA/Permit Non-Compliance

June 1, 2010 - June 30, 2010	0.5	mg/L	mon avg	1 exceedance	0.58	0.58	Equipment Modified - Repaired - Replaced or Re- calibrated	Assessment Complete - Incident Resolved
August 1, 2010 - August 31, 2010	0.5	mg/L	mon avg	1 exceedance	1.28	1.28	Conducting Study	Assessment Underway

**Total CofA/Permit Non-Compliance = 2 exceedances**

#### SUSPENDED SOLIDS

##### CofA/Permit Non-Compliance

June 1, 2010 - June 30, 2010	10	mg/L	mon avg	1 exceedance	18	18	Equipment Modified - Repaired - Replaced or Re- calibrated	Assessment Complete - Incident Resolved
August 1, 2010 - August 31, 2010	10	mg/L	mon avg	1 exceedance	53.5	53.5	Conducting Study	Assessment Underway
October 1, 2010 - October 31, 2010	10	mg/L	mon avg	1 exceedance	17	17	Action Plan Submitted - Implementing Improvements	Assessment Complete - No Action Required

**Total CofA/Permit Non-Compliance = 3 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of Alfred and Plantagenet

Lot 6, Conc. 5  
Alfred and Plantagenet

**Sector:** Municipal Sewage  
**Ministry Office:** Cornwall

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### SUSPENDED SOLIDS

#### CofA/Permit Non-Compliance

May 04, 2010	25	mg/L	seasonal avg	1 exceedance	34.9	34.9	Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway
--------------	----	------	-----------------	--------------	------	------	--	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of Asphodel-Norwood

34 Industrial Dr  
Asphodel-Norwood

**Sector:** Municipal Sewage  
**Ministry Office:** Peterborough

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### PHOSPHORUS

#### CofA/Permit Non-Compliance

January 26, 2010	0.62	mg/L	/d	1 exceedance	0.24	0.62	Equipment Modified - Repaired - Replaced or Re- calibrated, Operational Process Modification, Other	Other Abatement Action Taken
------------------	------	------	----	--------------	------	------	--	------------------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

### TOTAL AMMONIA NITROGEN

#### CofA/Permit Non-Compliance

April 05, 2010	6.6	mg/L	/d	1 exceedance	7.6	7.6	Additional Monitoring Underway, Equipment Modified - Repaired - Replaced or Re-calibrated	Assessment Complete - Incident Resolved
----------------	-----	------	----	--------------	-----	-----	--	--

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of Brooke-Alvinston

3084 River St  
Brooke-Alvinston

**Sector:** Municipal Sewage  
**Ministry Office:** Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### ESCHERICHIA COLI

#### CofA/Permit Non-Compliance

February 1, 2010 - February 28, 2010	200	CT/100 mL	mon avg. on a geo. mean density	1 exceedance	266	266	None Required	Assessment Complete - No Action Required
---	-----	--------------	--	--------------	-----	-----	---------------	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of Champlain

6489 Newton Road Vankleek Hill  
Champlain

**Sector:** Municipal Sewage  
**Ministry Office:** Cornwall

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>TOTAL AMMONIA NITROGEN</b>								
<b>CofA/Permit Non-Compliance</b>								
April 07, 2010	1.6	mg/L	any	4 exceedances	1.96	3.29	Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway
May 3, 2010 - May 7, 2010	1.6	mg/L	any	3 exceedances	2.57	3.07	Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway
December 01, 2010	1.7	mg/L	any	1 exceedance	1.94	1.94	Action Plan Submitted - Implementing Improvements, Ceased Operations	Voluntary Abatement Program Underway

**Total CofA/Permit Non-Compliance = 8 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of Clearview

Lot 26 Conc 2  
Clearview

**Sector:** Municipal Sewage  
**Ministry Office:** Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### SUSPENDED SOLIDS

#### CofA/Permit Non-Compliance

March 1, 2010 - March 31, 2010	15	mg/L	mon avg	1 exceedance	20.7	20.7	Additional Monitoring Underway, Operational Process Modification	Other Abatement Action Taken
-----------------------------------	----	------	---------	--------------	------	------	--	------------------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of Cramahe

1108 Ontario Street  
Cramahe

**Sector:** Municipal Sewage  
**Ministry Office:** Peterborough

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### AMMONIUM

##### CofA/Permit Non-Compliance

May 15, 2010 - September 30, 2010	2	mg/L	seasonal avg	1 exceedance	2.73	2.73	New Equipment or Treatment Process Installed	Assessment Complete - No Action Required
--------------------------------------	---	------	-----------------	--------------	------	------	---	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of Ear Falls - Ear Falls Wastewater Treatment Plant

KM275 Part 1 Aspen St  
Ear Falls

**Sector:** Municipal Sewage  
**Ministry Office:** Kenora

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>ESCHERICHIA COLI</b>								
<b>CofA/Permit Non-Compliance</b>								
October 1, 2010 - October 31, 2010	200	cfu/100 ml	mon avg	1 exceedance	2420	2420	Other	Assessment Complete - No Action Required

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of Enniskillen

East 1/2 of Lot 17, Concession 3  
Enniskillen

**Sector:** Municipal Sewage  
**Ministry Office:** Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### PHOSPHORUS

#### Policy/Guideline Non-Conformance

May 1, 2010 - May 31, 2010	1	mg/L	mon avg	1 exceedance	2	2	New Equipment or Treatment Process Installed	Assessment Underway
-------------------------------	---	------	---------	--------------	---	---	---	---------------------

**Total Policy/Guideline Non-Conformance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of Essa

143 Centre St  
Essa

**Sector:** Municipal Sewage  
**Ministry Office:** Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>SUSPENDED SOLIDS</b>								
<b>CofA/Permit Non-Compliance</b>								
October 1, 2010 - October 31, 2010	10	mg/L	mon avg	1 exceedance	15.5	15.5	Equipment Modified - Repaired - Replaced or Re- calibrated	Assessment Complete - No Action Required

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of Huron-Kinloss - Ripley Lagoons

Lot: Part of Lot 14, Conc 7, County of Bruce  
Huron-Kinloss

**Sector:** Municipal Sewage  
**Ministry Office:** Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### SUSPENDED SOLIDS

##### CofA/Permit Non-Compliance

February 24, 2010	30	mg/L	seasonal avg	1 exceedance	38.6	38.6	Other	Assessment Underway
-------------------	----	------	-----------------	--------------	------	------	-------	---------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of Lucan Biddulph - Granton WPCP

34195 Granton Line  
Lucan Biddulph

**Sector:** Municipal Sewage  
**Ministry Office:** London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### SUSPENDED SOLIDS

##### CofA/Permit Non-Compliance

January 1, 2010 - January 31, 2010	10	mg/L	mon avg	1 exceedance	10.75	10.75	None Required	Assessment Complete - No Action Required
---------------------------------------	----	------	---------	--------------	-------	-------	---------------	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of Manitouwadge

Lot M179, Concession BLKA  
Manitouwadge

**Sector:** Municipal Sewage  
**Ministry Office:** Thunder Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>BIOCHEMICAL OXYGEN DEMAND</b>								
<b>CofA/Permit Non-Compliance</b>								
May 17, 2010	25	mg/L	/2wk	1 exceedance	48.1	48.1	Equipment Modified - Repaired - Replaced or Re- calibrated	Additional Requirements Added in Certificate of Approval/Permit
May 03, 2010	25	mg/L	/2wk	3 exceedances	34.3	48.1	Operational Process Modification	Additional Requirements Added in Certificate of Approval/Permit

**Total CofA/Permit Non-Compliance = 4 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of Mapleton - Mapleton WPCP

7101 Side road 15 Drayton  
Mapleton

**Sector:** Municipal Sewage  
**Ministry Office:** Guelph

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### CARBONACEOUS BIOCHEMICAL OXYGEN DEMAND

#### CofA/Permit Non-Compliance

April 1, 2010 - April 30, 2010	7.5	mg/L	mon avg	1 exceedance	8.5	8.5	Other	Assessment Complete - Incident Resolved
-----------------------------------	-----	------	---------	--------------	-----	-----	-------	--

**Total CofA/Permit Non-Compliance = 1 exceedance**

### TOTAL AMMONIA NITROGEN

#### CofA/Permit Non-Compliance

April 1, 2010 - April 30, 2010	5	mg/L	mon avg	1 exceedance	5.6	5.6	Other	Assessment Complete - Incident Resolved
-----------------------------------	---	------	---------	--------------	-----	-----	-------	--

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of McGarry

McGarry Mining Claim MC L5414 PCL 348CST  
McGarry Township

**Sector:** Municipal Sewage  
**Ministry Office:** Timmins

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### PHOSPHORUS

#### CofA/Permit Non-compliance

February 1, 2010 - September 30, 2010	0.5	mg/L	mon avg	7 exceedances	0.507	0.89	Action Plan Submitted - Implementing Improvements	Voluntary Abatement Program Underway
--	-----	------	---------	---------------	-------	------	--	---

**Total CofA/Permit Non-compliance = 7 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of North Dundas - Chesterville Sewage Lagoon

Lot 20, Conc 4, (formerly Winchester Twp)  
North Dundas

**Sector:** Municipal Sewage  
**Ministry Office:** Cornwall

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### SUSPENDED SOLIDS

##### Policy/Guideline Non-Conformance

January 1, 2010 - December 31, 2010	25	mg/L	annual avg	1 exceedance	27.4	27.4	Other	Other Abatement Action Taken
--	----	------	------------	--------------	------	------	-------	------------------------------

**Total Policy/Guideline Non-Conformance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of North Dundas - Winchester Sewage Treatment Plant

12396 Ottawa St N  
North Dundas

**Sector:** Municipal Sewage  
**Ministry Office:** Cornwall

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### HYDROGEN SULPHIDE

##### CofA/Permit Non-Compliance

March 30, 2010 - April 27, 2010	0.01	mg/L	any	6 exceedances	0.29	0.29	Additional Monitoring Underway, Conducting Study	Voluntary Abatement Program Underway
------------------------------------	------	------	-----	---------------	------	------	---	---

**Total CofA/Permit Non-Compliance = 6 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of North Glengarry

McCormick Rd  
North Glengarry

**Sector:** Municipal Sewage  
**Ministry Office:** Cornwall

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### ESCHERICHIA COLI

#### CofA/Permit Non-Compliance

October 1, 2010 - October 31, 2010	200	cfu/100 ml	mon avg	1 exceedance	435	435	Action Plan Submitted - Implementing Improvements, New Equipment or Treatment Process Installed	Other Abatement Action Taken
---------------------------------------	-----	---------------	---------	--------------	-----	-----	--	------------------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of North Huron - Blyth Wastewater Treatment Plant

Lot: 42, Conc 1, County of Huron  
North Huron

**Sector:** Municipal Sewage  
**Ministry Office:** Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### SUSPENDED SOLIDS

##### CofA/Permit Non-Compliance

May 1, 2010 - May 31, 2010	5	mg/L	mon avg	1 exceedance	5.5	5.5	New Equipment or Treatment Process Installed, Operational Process Modification	Assessment Complete - Incident Resolved
-------------------------------	---	------	---------	--------------	-----	-----	--	--

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of North Huron - Wingham Sewage Treatment Plant

Lot: 41, Conc 14, County of Huron  
North Huron

**Sector:** Municipal Sewage  
**Ministry Office:** Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### BIOCHEMICAL OXYGEN DEMAND

#### CofA/Permit Non-Compliance

December 22, 2010	25	mg/L	/d	1 exceedance	30	30	None Required	Assessment Complete - No Action Required
-------------------	----	------	----	--------------	----	----	---------------	--

**Total CofA/Permit Non-Compliance = 1 exceedance**

### ESCHERICHIA COLI

#### CofA/Permit Non-Compliance

October 06, 2010	200	cfu/100 ml	mon avg. on a geo. mean density	1 exceedance	220	220	Equipment Modified - Repaired - Replaced or Re-calibrated	Voluntary Abatement Program Underway
------------------	-----	------------	---------------------------------	--------------	-----	-----	---	--------------------------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of North Stormont

Lot 22, Conc 7  
North Stormont

**Sector:** Municipal Sewage  
**Ministry Office:** Cornwall

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>TOTAL AMMONIA NITROGEN</b>								
<b>CofA/Permit Non-Compliance</b>								
April 10, 2010	15	mg/L	/d	2 exceedances	15.3	17.9	Action Plan Submitted - Implementing Improvements, Additional Monitoring Underway, Conducting Study	Provincial Officer's Order Issued
May 02, 2010	15	mg/L	/d	3 exceedances	16.2	18.7	Action Plan Submitted - Implementing Improvements, Additional Monitoring Underway, Conducting Study	Provincial Officer's Order Issued

**Total CofA/Permit Non-Compliance = 5 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of Perth East

3976 Galt St  
Perth East

**Sector:** Municipal Sewage  
**Ministry Office:** London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>TOTAL AMMONIA NITROGEN</b>								
<b>CofA/Permit Non-Compliance</b>								
November 1, 2010 - November 30, 2010	3	mg/L	mon avg	1 exceedance	18.04	18.04	Other	Assessment Complete - No Action Required
December 1, 2010 - December 31, 2010	3	mg/L	mon avg	1 exceedance	7.52	7.52	Other	Assessment Complete - No Action Required

**Total CofA/Permit Non-Compliance = 2 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of Ramara

155 Laguna Parkway or Part Lot 14 Conc 5  
Ramara

**Sector:** Municipal Sewage  
**Ministry Office:** Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### CARBONACEOUS BIOCHEMICAL OXYGEN DEMAND

#### CofA/Permit Non-Compliance

March 1, 2010 - March 31, 2010	10	mg/L	mon avg	1 exceedance	15.2	15.2	None required	Assessment Complete - No Action Required
May 1, 2010 - May 31, 2010	10	mg/L	mon avg	1 exceedance	13	13	None required	Assessment Complete - No Action Required

**Total CofA/Permit Non-Compliance = 2 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of Schreiber

608 Winnipeg Street  
Schreiber

**Sector:** Municipal Sewage  
**Ministry Office:** Thunder Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### LOW PH EFFLUENT

#### CofA/Permit Non-Compliance

January 21, 2010 - December 31, 2010	6	pH	any	80 exceedances	4	5.9	Equipment Modified - Repaired - Replaced or Re- calibrated, New Equipment or Treatment Process Installed	Assessment Underway
---	---	----	-----	----------------	---	-----	---	---------------------

**Total CofA/Permit Non-Compliance = 80 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of South Dundas

Golf Club Road, Iroquois  
South Dundas

**Sector:** Municipal Sewage  
**Ministry Office:** Cornwall

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### SUSPENDED SOLIDS

#### Policy/Guideline Non-Conformance

January 1, 2010 - December 31, 2010	70	% remova 1	annual average	1 exceedance	59.9	59.9	Other	Other Abatement Action Taken
--	----	------------------	-------------------	--------------	------	------	-------	------------------------------

**Total Policy/Guideline Non-Conformance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of Southgate - Dundalk Sewage Treatment Works

Part Lots 238 and 239, Conc 2, Proton  
Southgate

**Sector:** Municipal Sewage  
**Ministry Office:** Owen Sound

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### PHOSPHORUS

##### CofA/Permit Non-Compliance

March 1, 2010 - March 31, 2010	0.8	mg/L	mon avg	1 exceedance	0.88	0.88	None Required	Assessment Complete - No Action Required
-----------------------------------	-----	------	---------	--------------	------	------	---------------	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

#### SUSPENDED SOLIDS

##### CofA/Permit Non-Compliance

April 1, 2010 - April 30, 2010	10	mg/L	mon avg	1 exceedance	11.6	11.6	None Required	Assessment Complete - No Action Required
-----------------------------------	----	------	---------	--------------	------	------	---------------	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Township of Tehkummah

Lot 11, Conc 12, Tehkummah Township  
Tehkummah

**Sector:** Municipal Sewage  
**Ministry Office:** Sudbury

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### SUSPENDED SOLIDS

#### CofA/Permit Non-Compliance

November 1, 2010 - November 30, 2010	40	mg/L	/mon	1 exceedance	43	43	Other	Assessment Underway
---	----	------	------	--------------	----	----	-------	---------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Village of Burk's Falls - Burk's Falls Lagoon

Lagoon Rd  
Burk's Falls

**Sector:** Municipal Sewage  
**Ministry Office:** North Bay

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

#### SUSPENDED SOLIDS

##### Policy/Guideline Non-Conformance

May 13, 2010 - May 25, 2010	25	ppm	seasonal avg	1 exceedance	33	33	None Required	Assessment Complete - No Action Required
--------------------------------	----	-----	-----------------	--------------	----	----	---------------	---

**Total Policy/Guideline Non-Conformance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Village of Casselman

224 Laurier Street  
Casselman

**Sector:** Municipal Sewage  
**Ministry Office:** Cornwall

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>TOTAL AMMONIA NITROGEN</b>								
<b>CofA/Permit Non-Compliance</b>								
November 15, 2010 - November 29, 2010	5	mg/L	seasonal avg	1 exceedance	5.74	5.74	Action Plan Submitted - Implementing Improvements, Conducting Study	Voluntary Abatement Program Underway

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Corporation of the Village of Merrickville-Wolford

106 Collar Hill Rd  
Merrickville-Wolford

**Sector:** Municipal Sewage  
**Ministry Office:** Kingston

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>ESCHERICHIA COLI</b>								
<b>CofA/Permit Non-Compliance</b>								
March 31, 2010 - December 31, 2010	200	cfu/100 ml	mon avg	6 exceedances	206.6	675	Other	Voluntary Abatement Program Underway

**Total CofA/Permit Non-Compliance = 6 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

**The District Municipality of  
Muskoka**

2825 Muskoka Road 117  
Lake of Bays

**Sector:** Municipal Sewage  
**Ministry Office:** Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>CARBONACEOUS BIOCHEMICAL OXYGEN DEMAND</b>								
<b>CofA/Permit Non-Compliance</b>								
March 1, 2010 - March 31, 2010	15	mg/L	mon avg	1 exceedance	24.4	24.4	Additional Monitoring Underway	Assessment Complete - Incident Resolved
April 1, 2010 - April 30, 2010	15	mg/L	mon avg	2 exceedances	24.4	194.96	Additional Monitoring Underway	Assessment Complete - No Action Required

**Total CofA/Permit Non-Compliance = 3 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Forest-Cliff Camps, Incorporated

8324 Glendale Dr  
Lambton Shores

**Sector:** Miscellaneous Communal  
**Ministry Office:** Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### PHOSPHORUS

#### CofA/Permit Non-Compliance

August 1, 2010 - August 31, 2010	0.5	mg/L	mon avg	1 exceedance	1.32	1.32	Operational Process Modification	Assessment Underway
September 1, 2010 - September 30, 2010	0.5	mg/L	mon avg	1 exceedance	0.96	0.96	New Equipment or Treatment Process Installed	Additional Requirements Added in Certificate of Approval/Permit

**Total CofA/Permit Non-Compliance = 2 exceedances**

### SUSPENDED SOLIDS

#### CofA/Permit Non-Compliance

May 1, 2010 - May 31, 2010	10	mg/L	mon avg	1 exceedance	72	72	None Required	Assessment Complete - No Action Required
-------------------------------	----	------	---------	--------------	----	----	---------------	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

### TOTAL AMMONIA NITROGEN

#### CofA/Permit Non-Compliance

July 1, 2010 - July 31, 2010	3	mg/L	mon avg	1 exceedance	26	26	Operational Process Modification	Assessment Underway
August 1, 2010 - August 31, 2010	3	mg/L	mon avg	1 exceedance	3.55	3.55	Operational Process Modification	Assessment Underway

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

---

**The Forest-Cliff Camps,  
Incorporated**

8324 Glendale Dr  
Lambton Shores

**Sector:** Miscellaneous Communal  
**Ministry Office:** Sarnia

---

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
Total CofA/Permit Non-Compliance = 2 exceedances								

---

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Municipality of Middlesex Centre - Ilderton Waste Water Treatment Plant

147 Meadowcreek Dr Part of Lot 24, Conc 10  
Middlesex Centre

**Sector:** Municipal Sewage  
**Ministry Office:** London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>LOW PH EFFLUENT</b>								
<b>CofA/Permit Non-Compliance</b>								
November 06, 2010	6	pH	any	1 exceedance	5.35	5.35	Equipment Modified - Repaired - Replaced or Re- calibrated, Operational Process Modification	Assessment Underway

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Municipality of North Perth

330 Wallace Avenue  
North Perth

**Sector:** Municipal Sewage  
**Ministry Office:** London

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### ESCHERICHIA COLI

#### CofA/Permit Non-Compliance

February 1, 2010 - February 28, 2010	200	CT/100 mL	mon avg. on a geo. mean density	1 exceedance	661	661	Operational Process Modification	Assessment Complete - Incident Resolved
---	-----	--------------	--	--------------	-----	-----	-------------------------------------	--

**Total CofA/Permit Non-Compliance = 1 exceedance**

### TOTAL AMMONIA NITROGEN

#### CofA/Permit Non-Compliance

January 1, 2010 - January 31, 2010	3.62	mg/L	mon avg	1 exceedance	9.02	9.02	Operational Process Modification	Assessment Complete - Incident Resolved
January 1, 2010 - January 31, 2010	32.8	kg/d	mon avg	1 exceedance	34.8	34.8	Operational Process Modification	Assessment Complete - Incident Resolved

**Total CofA/Permit Non-Compliance = 2 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Regional Municipality of Halton - Oakville Southwest

1385 Lakeshore Rd W Lot 23,24  
Oakville

**Sector:** Municipal Sewage  
**Ministry Office:** Halton-Peel

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### PHOSPHORUS

#### CofA/Permit Non-Compliance

September 1, 2010 - September 30, 2010	1	mg/L	mon avg	1 exceedance	1.07	1.07	None Required	Assessment Complete - No Action Required
---	---	------	---------	--------------	------	------	---------------	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Regional Municipality of Niagara - Niagara Falls WPCP

3450 Stanley Ave  
Niagara Falls

**Sector:** Municipal Sewage  
**Ministry Office:** Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### CARBONACEOUS BIOCHEMICAL OXYGEN DEMAND

#### CofA/Permit Non-Compliance

October 1, 2010 - October 31, 2010	25	mg/L	mon avg	1 exceedance	29.8	29.8	Training/Procedure Change	Voluntary Abatement Program Underway
---------------------------------------	----	------	---------	--------------	------	------	---------------------------	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

### ESCHERICHIA COLI

#### CofA/Permit Non-Compliance

October 1, 2010 - October 31, 2010	200	cfu/100 ml	mon avg. on a geo. mean density	1 exceedance	365	365	Training/Procedure Change	Voluntary Abatement Program Underway
---------------------------------------	-----	---------------	--	--------------	-----	-----	---------------------------	---

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Regional Municipality of Niagara - Queenston Wastewater Treatment Plant

30 Front Street  
Queenston

**Sector:** Municipal Sewage  
**Ministry Office:** Niagara

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>PHOSPHORUS</b>								
<b>Policy/Guideline Non-Conformance</b>								
January 31, 2010 - December 31, 2010	1	mg/L	mon avg	12 exceedances	1.97	5.87	Conducting Study	Assessment Underway

**Total Policy/Guideline Non-Conformance = 12 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Regional Municipality of Waterloo - Kitchener WPCP

368 Mill Park Dr  
Kitchener

**Sector:** Municipal Sewage  
**Ministry Office:** Guelph

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>ESCHERICHIA COLI</b>								
<b>CofA/Permit Non-Compliance</b>								
July 1, 2010 - July 31, 2010	200	cfu/100 ml	mon avg. on a geo. mean density	1 exceedance	387	387	Action Plan Submitted - Implementing Improvements, Additional Monitoring Underway, Conducting Study, New/Modified Sampling Program Underway	Other Abatement Action Taken

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Regional Municipality of York - Sutton Water Pollution Control Plant

5741 Black River Rd Sutton  
Georgina

**Sector:** Municipal Sewage  
**Ministry Office:** York-Durham

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>TOTAL AMMONIA NITROGEN</b>								
<b>CofA/Permit Non-Compliance</b>								
March 1, 2010 - March 31, 2010	3	mg/L	mon avg	1 exceedance	6.62	6.62	Equipment Modified - Repaired - Replaced or Re- calibrated	Assessment Complete - No Action Required

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### The Rosseau Resort Developments Inc.

Part of Lots 24 and 25 Conc 11 and 12  
Muskoka Lakes

**Sector:** Miscellaneous Communal  
**Ministry Office:** Barrie

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>TOTAL AMMONIA NITROGEN</b>								
<b>CofA/Permit Non-Compliance</b>								
February 1, 2010 - February 28, 2010	2.5	mg/L	mon avg	1 exceedance	2.81	2.81	Operational Process Modification	Assessment Complete - No Action Required
July 1, 2010 - July 31, 2010	2.5	mg/L	mon avg	1 exceedance	10.69	10.69	Operational Process Modification	Voluntary Abatement Program Underway
August 1, 2010 - August 31, 2010	2.5	mg/L	mon avg	1 exceedance	5.95	5.95	Operational Process Modification	Voluntary Abatement Program Underway

**Total CofA/Permit Non-Compliance = 3 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Union Gas Limited

3332 Bentpath Line  
Dawn-Euphemia

**Sector:** Miscellaneous Communal  
**Ministry Office:** Sarnia

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### DISSOLVED OXYGEN

#### CofA/Permit Non-Compliance

July 1, 2010 - July 31, 2010	5	mg/L	mon avg	1 exceedance	4.75	4.75	Action Plan Submitted - Implementing Improvements, Conducting Study	Provincial Officer's Order Issued
---------------------------------	---	------	---------	--------------	------	------	---	--------------------------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

### ESCHERICHIA COLI

#### CofA/Permit Non-Compliance

May 31, 2010 - July 31, 2010	200	CT/100 mL	mon avg. on a geo. mean density	2 exceedances	335	812	Action Plan Submitted - Implementing Improvements, Conducting Study	Provincial Officer's Order Issued
---------------------------------	-----	--------------	--	---------------	-----	-----	---	--------------------------------------

**Total CofA/Permit Non-Compliance = 2 exceedances**

### SUSPENDED SOLIDS

#### CofA/Permit Non-Compliance

May 31, 2010 - August 31, 2010	10	mg/L	mon avg	2 exceedances	10.5	13	Action Plan Submitted - Implementing Improvements, Conducting Study	Provincial Officer's Order Issued
-----------------------------------	----	------	---------	---------------	------	----	---	--------------------------------------

**Total CofA/Permit Non-Compliance = 2 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Upper Grand District School Board - Erin High School

14 Boland Dr Erin  
Wellington North

**Sector:** Miscellaneous Communal  
**Ministry Office:** Guelph

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
------	-------	------	-----------	--------------------	------	------	-----------------	-----------------

### NITRATE

#### CofA/Permit Non-Compliance

December 1, 2010 - December 31, 2010	3.6	mg/L	mon avg	1 exceedance	27.9	27.9	Operational Process Modification	Other Abatement Action Taken
---	-----	------	---------	--------------	------	------	-------------------------------------	------------------------------

**Total CofA/Permit Non-Compliance = 1 exceedance**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.

## 2010 Municipal/Private Sewage Monthly Summary - All Regions

### Wellington Catholic District School Board - St. John Brebeuf

30 Millwood Rd  
Erin

**Sector:** Miscellaneous Communal  
**Ministry Office:** Guelph

Date	Limit	Unit	Frequency	No. of Exceedances	Min.	Max.	Facility Action	Ministry Action
<b>NITRATE</b>								
<b>CofA/Permit Non-Compliance</b>								
January 31, 2010	3.5	mg/L	rolling avg	1 exceedance	6.48	6.48	Other	Assessment Underway
February 28, 2010	3.5	mg/L	rolling avg	1 exceedance	5.23	5.23	Other	Assessment Underway
April 30, 2010	3.5	mg/L	rolling avg	1 exceedance	3.55	3.55	Other	Assessment Underway
October 31, 2010	3.5	mg/L	rolling avg	1 exceedance	16.8	16.8	Conducting Study	Other Abatement Action Taken

**Total CofA/Permit Non-Compliance = 4 exceedances**

This data is provided for information purposes only. Dischargers provide most of the information contained in this summary. Dischargers are accountable for the accuracy of the information that they submit. Some of the information is also derived from ministry data on discharges. Facility Action, Ministry Action and conviction information are all current to August 2011. For up-to-date information, please contact the appropriate district or area office.